

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 63052
Edition 1.0 2019-08

IEC 63052
Édition 1.0 2019-08

**Power frequency overvoltage protection devices
(POPs) for household and similar applications**

**Dispositifs de protection contre les surtensions
à fréquence industrielle (POP) pour les
applications domestiques et similaires**

C O R R I G E N D U M 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

Replace Figure 4 and its title with the following new figure and title:




Figure 4 – Typical diagram for all short circuit tests except for the verification of the suitability in IT systems

In "Explanation of letter symbols used in Figure 4, Figure 5 and Figure 6":

– add, under the line under " Z_1 ", the following new line:

Z_2 = Adjustable impedance for the calibration of I_{m1} and I_{nc1} .

– on the line I_1 , I_2 , I_3 , add " I_4 ".

Replace the title to Figure 5 with the following new title:

Figure 5 – Typical diagram for the verification of the suitability in IT systems

Annex A, Clause A.1

Replace the existing sentences: